



DECLARATION OF PERFORMANCE

No. 25281802R01-0037-CPR-18

Unique identification code of the product-type:	K-FLEX K-FIRE COLLAR-E - Penetration
Intended use/es:	Fire stopping and fire sealing products - Penetration seals. See ETA-21/0564 - EAD 350454-00-1104
Manufacturer:	L'Isolante K-Flex Spa, Via Don Locatelli 35, 20877 Roncello (MB), ITALY
System/s of AVCP:	1
Harmonised standard:	Not available
Notified body:	DBI Certification A/S
European Technical Approval Certificate of Conformity	ETA-21/0564 - EAD 350454-00-1104 2531-CPR-CXO10227 DBI Certification A/S performed third party tasks as set out in Annex V under System 1 and issued Certificate of Conformity.

Declared performance/s:

Essential Characteristics	Performance
BWR 1 - Mechanical Resistance and stability	
Mechanical Resistance and stability	NR
BWR 2 - Safety in case of fire	
Reaction to fire	NPD
Resistance to Fire	ETA-21/0564 - Annex A
BWR 3 - Hygiene, health and environment	
Air Permeability	ETA-21/0564 - Annex B
Release of dangerous substances	IA1, SW2
BWR 4 - Safety in use	
Mechanical Resistance and stability	NPD
Resistance to impact/movement	NPD
Adhesion	NPD
BWR 5 - Protection against noise	
Airborne sound insulation	Rw(C;Ctr)= 58 (-1;-7) dB
BWR 6 - Energy economy and heat retention	
Thermal properties	NPD
Water vapor permeability	NPD
General Aspect relating to fitness for use	
Durability and Serviceability	Z2 - Intended for uses in internal conditions with humidity lower than 85 % RH excluding temperatures below 0°C, without exposure to rain or UV.

NR = Not Relevant.

NPD = No Performance Determined.

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 3052011, under the sole responsibility of the manufacturer identified above.

The Safety Data Sheet (SDS) of K-FLEX K-FIRE COLLAR-E - Penetration is available on request.

Roncello, 04/10/2021

Signed for and on behalf of the manufacturer by:



Amedeo Spinelli, President